

Drinking Water Lead Sample Results Table for the Lead Consumer Notice

(Safe Drinking Water Act, 1976 PA 399, as amended)

The table below lists the most recent drinking water quality lead sample results. Lead samples are collected where cold water is typically drawn for consumption, such as drinking fountains, kitchen and classroom sinks, and break room faucets. Each facility has an established sample siting plan to identify approved sample points, in addition to a predetermined monitoring frequency.

Water System Name : VESTABURG HIGH SCHOOL

WSSN : 2004359

<u>Sample Number</u>	<u>Sample Location</u>	<u>Sample Date</u>	<u>Results *</u> milligrams / liter	<u>Comment</u>
<u>Samples related to Source # 001</u>				
LH44242	CONCESSION LEFT FAUCET	9/27/2017	0	
LH44243	CONCESSION STAND (RIGHT) FAUCET	9/27/2017	0	
LH44244	SOUTH DE BY 2203	9/27/2017	0	
LH44245	3 COMP SINK RIGHT FAUCET	9/27/2017	0	
LH44246	2158 WORK ROOM SINK	9/27/2017	0	
LH44247	2112 TEACHER LOUNGE SINK	9/27/2017	0	
LH44248	BOYS LOCKER RM D.F	9/27/2017	0	
LH44249	WEST D.F BY ROOM 2402	9/27/2017	0	
LH44250	LOBBY UPPER DF	9/27/2017	0	
LH44251	2302 SCIENCE RM LOUNG 1 COMP SINK	9/27/2017	0	
LH44252	3 COMP SINK LEFT FAUCET	9/27/2017	0	
LH44254	RM 203 COMP SINK	9/27/2017	0	
LH44255	GIRLS LOCKER RM DF	9/27/2017	0	
LH44256	CAFE PRODUCE SINK SOFTENED	9/27/2017	0	
LH44259	LOBBY LOWER D.F.	9/27/2017	0	

*** All lead sample results will be reviewed by your local health department to assess compliance with lead regulations and to determine the 90th percentile value. Results that are below the detection limit of the analytical method employed by the laboratory are listed as zero.**

For information on the health effects of lead and reducing your exposure to lead, call the National Lead Information Center at 800-424-LEAD (5323), visit the U.S. EPA's Web site at www.epa.gov/lead, or contact your health care provider.

Printed: 10/5/2017